



NOTES:

1. ADEQUATE BARRICADES SHALL BE PLACED AND MAINTAINED UNTIL THE COLLAR ATTAINS A COMPRESSIVE STRENGTH OF 3000 PSI OR GREATER.
2. DURACAL GROUT SHALL BE A MIXTURE OF 100 LBS DURACAL, 26 LBS WATER (3.12 GALLONS) AND 100 LBS OF SAND CONFORMING TO ASTM C-35.

Drawn By: SBW *[Signature]*
 Checked By: *[Signature]*
 Approved By: *[Signature]*

MANHOLE RING AND COVER
ADJUSTMENT

Issued: 5/10/05

Revised: 8/31/06

Drawing Number:
SP. 15